

Northwestern Health Unit

3853-78

APPLICATION FOR CERTIFICATE OF APPROVAL TO INSTALL A SEWAGE SYSTEM

1. Owner WILLIAM ZURKAN Address GEN. DEL. KEEWATIN Telephone No. 543-2182
 2. Location of site BESIDE HOUSE District KENORA Twp. PELLAT Plan _____
 Lot No. 7 Con./Sec. Z Type of Water Supply LAKE WATER

3. Propose to Construct Install - Alter - Enlarge a class 4 sewage system to serve single family or other _____
 4. State No. of: Bedrooms 2 People 4 Flush Toilets 1 Urinals 0 Washbasins 1 Shower/Bathtubs 1
 Laundry Tubs 0 Kitchen Sinks 1 Garbage Grinder 0 Dishwasher 0 Auto. Wash. Machine 0 Other _____

5. Lot approval pending _____ Lot approved Severence Application No. _____

6. Directions to Lot 2.2 mi. N. on Hwy 641, 800' E. of Hwy BESIDE YELLOW H

7. I certify that the above information is complete and correct and that, if approved, the work will conform with the Provincial requirements for sewage systems and local municipal by-laws.

Name WILLIAM ZURKAN Address GEN. DEL. KEEWATIN ONT.
 (Owner or Agent) Date OCT. 4/78

8. INSPECTOR'S REPORT Date Inspected Oct. 12/78

Requirements: Working Capacity of septic tank/~~holding tank~~ 600 gal.
 Length of Distribution pipe 270'

Depth	Soil Condition
1'	7 clay
2'	
3'	
4'	
5'	

- Excavate to a depth of 3 ft. and level proposed field bed area approx. 40 ft. x 55 ft.;
- Then on 3 ft. of gravel fill and 6 ins. of crushed stone lay level at 6 ft. centres from a header line or distribution box 6 lines each 45 ft. long of PVC or No co rode perforated piping;
- Tie ends with T's and solid piping;
- Mound 4 ins. of crushed stone over lines;
- Cover the lines with untreated building paper;
- Cover the field bed area with 18 ins. of sand and gravel;
- Bank sides of field with clay - slope 2:1
- Sod or seed entire field.

NOTE: System to be re-inspected before covering and signature obtained below.

9. APPLICATION: Approved/~~Not Approved~~ This approval is valid 12 months from date of issue. Do not operate the system until a Use Permit has been issued.

Atkinson
Director

Inspected and Recommended by J. Havingson Date OCT 12/78

USE PERMIT

Under Sec. 59A Environmental Protection Act 1971/and Regulations thereunder, permission is granted for the above mentioned sewage system to be used. System is satisfactorily installed as per application and/or the following amendments:

- laid as per specifications
- Note - Tank - Barkman steel - installed in 74

Atkinson
Director

Inspected and Recommended by J. Havingson Date OCT 19/78